



221121341889



中国认可  
国际互认  
检测  
TESTING  
CNAS L9459

# 检测报告



Test Report

报	告	编	号	:	TY20250328003
产	品	名	称	:	龙骨
委	托	单	位	:	创意玩家(中山)家居有限公司
检	测	类	别	:	委托检测

浙江天耀消防材料检测服务有限公司

ZheJiang TianYao Fire-Fighting Equipment Detection Service CO.,LTD



浙江天耀消防材料检测服务有限公司

检测报告

No. TY20250328003

共 3 页    第 1 页

样品名称	龙骨	燃烧等级	B <sub>1</sub> (C) 级		
检测依据	GB/T 11785-2005 《铺地材料的燃烧性能测定 辐射热源法》 GB/T 8626-2007 《建筑材料可燃性试验方法》				
判定标准	GB 8624-2012 《建筑材料及制品燃烧性能分级》				
生产单位	委托方标称：创意玩家(中山)家居有限公司		检测类别	委托检测	
委托单编号	20250328003		样品编号	20250328003	
来样数量	3 平方米		样品状态	可检	
是否留样	客户未提供留样样品		收样日期	2025 年 03 月 28 日	
检测项目	燃烧性能、可燃性		检测日期	2025 年 03 月 31 日	
检测设备	序号	设备名称	规格型号	设备编号	检测状态
	1	铺地材料燃烧性能检测仪	SY-PD	JC024	正常
	2	建材可燃性试验炉	JCK-2	JC008	正常
检测结论	按客户委托，对委托方送检样品的燃烧性能、可燃性进行检测，结果符合 GB 8624-2012 《建筑材料及制品燃烧性能分级》中 B <sub>1</sub> (C) 级的要求。 签发日期：2025 年 03 月 31 日				
备注	1. 样品已按标准养护。				
	2. 本试验结果只与制品的试样在特定试验条件下的性能相关，不能将其作为评价该制品在实际使用中潜在火灾危险性的唯一依据。				

编制：       审核：       批准： 



# 浙江天耀消防材料检测服务有限公司

## 检测报告

No. TY20250328003

共 3 页 第 2 页

序号	检测项目	判定要求	单位	实测结果	单项评定	备注
1	燃烧性能	临界热辐射通量 $CHF \geq 4.5 \text{ kW/m}^2$	$\text{kW/m}^2$	6.8	合格	/
2	可燃性	20s 内焰尖高度 $F_s \leq 150 \text{ mm}$	mm	42	合格	/

以下空白

浙江天耀消防材料检测服务有限公司

检测报告

No. TY20250328003

共 3 页      第 3 页

样品描述		
该 样 品 委 托 方	创意玩家(中山)家居有限公司	
委 托 方 地 址	广东省中山市港口镇沙港东路 2 号之五	
委托方 标称	工 程 项 目 名 称	/
	工 程 建 设 单 位	/
	工 程 地 址	/
	监 理 单 位	/
	施 工 单 位	/
样 品 说 明		按客户要求，样品由实验室代剪裁
样品照片		
样品编号：20250328003		
		



# 声 明

## Statement

一、本检测机构保证检测的公正性、科学性和准确性，对检测的数据负责，报告中由委托方提供的信息的真实性由委托方负责；

1.This testing institution guarantees the impartiality, scientific nature, and accuracy of its testing services and takes responsibility for the tested data. The authenticity of the information provided by the client in the report is the responsibility of the client.

二、本检测报告无编制、审核、批准人签字或涂改，或未盖本检测机构检测专用章、骑缝章无效；

2. This testing report is invalid if it does not bear the signatures of the preparer, reviewer, and approver, or if it has been altered, or if it does not carry the specialized testing seal and cross-page seal of this testing institution.

三、未经允许，不得部分复制本检测报告，复制的检测报告未盖本检测机构检测专用章、骑缝章无效；

3.No part of this testing report may be reproduced without permission. Any reproduced copy of the report that does not bear the specialized testing seal and cross-page seal of this testing institution is invalid.

四、对本报告中试验结果有异议者，请于收到报告之日起十五天内向本检测机构提出；

4.If there are any objections to the test results in this report, please raise them with this testing institution within fifteen days from the date of receiving the report.

五、本报告仅对样品所检项目的符合性情况负责，送检样品的代表性和真实性由委托方负责；

5.This report only takes responsibility for the conformity of the tested items of the sample. The representativeness and authenticity of the submitted sample are the responsibility of the client.

六、受检剩余样品务必在收到本试验报告半个月內領取，逾期不領者，又未提出妥善處理意見的，本檢測機構將按有關規定處理。

6.The remaining tested samples must be collected within half a month from the date of receiving this test report. If they are not collected within this period and no proper disposal opinion is provided, this testing institution will handle them according to relevant regulations.

七、不包含 CMA 资质认定标志的报告，检测数据和结果仅作为科研、教学或内部质量控制之用，不作为社会公正性数据。中英文报告内容以中文为准。

7.Reports that do not bear the CMA (China Metrology Accreditation) qualification mark are intended solely for use in scientific research, teaching, or internal quality control and are not considered as socially impartial data. In the case of discrepancies between the Chinese and English versions of the report, the Chinese version shall prevail.

八、本报告各页均为报告不可分割之部分，未完整使用本报告全文由此造成的任何不良后果，本机构不负相应的法律责任。

8.Each page of this report is an integral part of the whole report. This institution shall not bear corresponding legal responsibility for any adverse consequences arising from the incomplete use of the full text of this report.

地 址：杭州市萧山区所前镇所前北路 16 号 2 幢

邮 编：311254 电 话：0571-82783808 邮箱：yingye@zjtyxfcljcfwy.wecom.work

Add: Building 2, No. 16, Suoqian North Road, Suoqian Town, Xiaoshan District, Hangzhou

Postcode: 311254 Telephone: 0571-82783808 mail: yingye@zjtyxfcljcfwy.wecom.work